

Centro de Biologia Experimental Oceanus Ltda Laboratory of water analyses

REG.INEA:UN015590/55.11.10 CCL NºIN018913 CNPJ 28383198/0001-59. INSC. MUN. 313818-6 Almirante Cochrane street, 37, Tijuca, CEP 20550-040 - Rio de Janeiro, RJ, Tel-Fax- (55 - 21) 2567-0819 / 2567-3871

CERTIFICATION OF MEASUREMENT FOR WATER'S QUALITY Nº 66058

ESTABLISHMENT'S DATA				
CORPORATE NAME: C & C TECHNOLOGIES DO BRASIL LTDA				
NICKNAME: C & C TECHNOLOGIES				
ANDRESS: MAURÍCIO SILVA TELES STREET, 95 / 230				
NEIGHBORHOOD: BARRA DA TIJUCA	DISTRICT: RJ/RJ			
CITY: RIO DE JANEIRO	CEP:			
TELEPHONE: (21) 2408-6006	FAX:			

DATA SAMPLE				
SHIP: RIG SUPPORTER				
HARBOR: NITSHORE				

SAMPLE DATA				
SAMPLE ORIGIN: TRATED WATER				
COLLECTION POINT: MAIN TANK WITHOUT FILTER				
COLLECTION RESPONSABLE NAME: HAMILTON BARBOSA VOLUME: 2100mL				
SAMPLING HOUR: 13:20	SAMPLING DATE: 11.14.12			
ARRIVAL HOUR IN LABORATORY: 19:00	ARRIVAL DATE IN LABORATORY: 11.14.12			

ANALYTICAL RESEULTS OF THE SAMPLE						
Microbiological Analysis						
Parameters	Unit	Results ¹	MVA ²⁻³	QL		
Coliform count	MPN/100mL	< 1	Absence	1		
Fecal Coliform	MPN/100mL	< 1	Absence	1		
Escherichia coli	MPN/100mL	< 1	Absence	1		
Standart Plate count	CFU/mL	332	500	1		

ADOPTED METHODS

Microbiological Examination:

 ${\bf Coliform\ Count:\ SMEWW\ 9221-Multiple-tube\ Fermentation\ Technique\ for\ Members\ of\ the\ Coliform\ group;}$

Fecal Coliform: SMEWW 9221 - Multiple-tube Fermentation Technique;

Standart Plate Count: SMWW 9215 B; Escherichia coli: SMEWW 9221.



Centro de Biologia Experimental Oceanus Ltda Laboratory of water analyses

REG.INEA:UN015590/55.11.10 CCL №IN018913 CNPJ 28383198/0001-59. INSC. MUN. 313818-6 Almirante Cochrane street, 37, Tijuca, CEP 20550-040 - Rio de Janeiro, RJ, Tel-Fax- (55 - 21) 2567-0819 / 2567-3871

REFERENCES

- 1- Officers: MS n⁰ 2914 ANVISA of Health Department of 12th December, 2011. Standard of water potability destined to the human consumption.
- 2- Analytical methodology: Standard Methods for Examination of Water and Wastewater 20th Edition American Public Health Association APHA.
- 3- Agriculture Departament. National Secretariat of Farming Defense. Methods for Control of Products of Animal Origin and its ingredients. II Methods Physical and Chemical, 1981.

OBSERVATIONS

SUBTITLE:

- 1- Collected water referring results.
- 2- Nº 2914 ANVISA/MS limits
- 3 MVA: Maximum value allowed

QL: Quantification limit

MPN - Most Probable Number

CFU- colony forming units

- Note 1: These results restrict only the analyzed water.
- Note 2: This report can only be reproduced if complete.
- Note 3: The sample's collection follows the described procedures in POP COL 001.
- Note 4: The sample data provided are the responsibility of the applicant.

ANALYSES FINDING

The analyzed water is in the limits established for MS N.⁰ 2914 ANVISA

Rio de Janeiro, November 21 th, 2012.

PhD Ronaldo Leão Technical responsible CRBio-02339/85